

Fremont
Building Official
Code Enforcement

Thom Roy
PO Box 120
295 Main Street
Fremont, NH 03044
(603) 895-2226 x18
(603) 895-3149 (Fax)



NOTICE

Contractors, Builders, Installers, & Home Owners:

All venting; non-direct, direct, and power vents must be installed such that the vent is positioned a minimum of 12 inches above anything that could accumulate and block the vent. All vents are to be placed 12 inches above average snow accumulation.

Determine finished grade, add 18 to 24 inches for snow accumulations – position vent terminations above this point a minimum of 12 inches.

Improper installations can cause damage, personal injury and even loss of life. If installation instructions or codes otherwise prohibit installations in the manner above or installation manuals instruct otherwise please see the building official prior to installations.

Thom Roy
Building Inspector/Code Enforcement